



1. ALL INLET AND OUTLET PIPES SHALL BE INSTALLED NO MORE THAN 12" FROM THE BOTTOM OF THE GREASE TRAP.
2. TANK TAPERS TOP TO BOTTOM AND IS TRAPEZOIDAL IN CROSS SECTION.
3. TANK IS 4000 PSI CONCRETE-STEEL REINFORCED CONCRETE CONFORMS TO ACI 318-16-4.5.1 AND 318-16-5.4.2.
4. DIMENSION: 10'11"Lx5'6"Wx52"D (EXTERNAL DIMENSIONS)
5. WHEN LOCATED IN DRIVEWAYS OR PAVED AREAS, GREASE TRAP TO BE DESIGNED FOR APPROPRIATE LOAD BEARING CONDITIONS.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES COMMISSION STANDARD DETAILS GREASE TRAP
<i>Talbot W. Bane</i> 5/24/07		
EU MANAGER OF ENGINEERING DATE		
ISSUED: MAR 8, 2007		STANDARD NO. SS-9.20